

SCHOOL NAME: Pauline
Johnson

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Time to Complete Check (Minutes)	Requires Immediate Attention to Maintain Ventilation (Y/N)	Materials	Comments
AHU1	DJE20/0	B55437-AHU1	Top Roof East	Gym	45	N	20x25x4(2) 20x25x2(4) B59(1) B48(1)	HRV Wheel Not Operating, Belt Needs Adjustment
Unknown, EF	SDBDe08	SN599256-1	Top Roof East	Building	15	N		
Unknown, EF	SDBDe08	SN599256-2	Top Roof East	Building	15	N		Not Operable
Unknown, EF	6-080-VG-X	1.22246E+11	Low Roof East	Building	15	N		Not Operable
Unknown, EF	SDBDe10	SN599257-2	Low Roof East	Building	15	N		
Unknown, EF	6-080-VG-X	1.22246E+11	Low Roof East	Building	15	N		Not Operable
Unknown, EF	6-099-VG-X	1.22246E+11	Low Roof East	Building	15	N		Not Operable
EF4	Unknown	Unknown	Low Roof Central	Gym Storage	15	N		Not Operable
Unknown, EF	SBDBe16	SN599265-1	Low Roof Central	Building	15	N		Not Operable
Unknown, HP	MXZ-2B20NA	4273	Low Roof Central	Building	30	N		
AC1	PUY-A24NHA3	06U03623C	Low Roof East	Building	30	N		
AC2	PUY-A24NHA3	06U03534C	Low Roof East	Building	30	N		
CU2	LSU120HSV4	608KACA11507	Low Roof East	Building	15	N		
Unknown, EF	Unknown	Unknown	Low Roof East	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	Top Roof West	Building	15	N		Not Operable
MUA1	DJX60/0	S46947MUA	Top Roof West	Building	90	Y	16x20x2(3) 20x20x2(3) B70(1)	found unit failed , checked all and flame flame code, reset and checked , will have to check ignitor assy
Unknown, EF	Unknown	Unknown	Top Roof West	Building	15	N		Not Operable
Unknown, CU	MUY-D30NA	8000151T	Low Roof South	Building	15	N		
UV1/DX1	CAH 1000A NA VP DD	15691040J	Room 108	Room 108	30	N	16x20x1(2)	
UV2	RUV1600	Q2221-UV-3	Room 113	Room 113	30	N	16x20x2(2)	
UV4	RUV1600	Q2221-UV-4	Room 116	Room 116	30	N	16x20x2(2)	
UV1	RUV1600	Q2221-UV-1	Room 114	Room 114	30	N	16x20x2(2)	
UV3	RUV1600	Q2221-UV-2	Room 115	Room 115	30	N	16x20x2(2)	
UV7	RUV1200	Q2221-UV-6	Room 140	Room 140	30	N	20x24x2(1)	
UV6	RUV1200	Q2221-UV-5	Room 138	Room 138	30	N	20x24x2(1)	
UV5	RUV1200	Q2221-UV-7	Room 209	Room 209	30	N	20x24x2(1)	
Unknown, UV	CAE 4036 PA ERWE DD	1004881682-2100A-002	Portable	Portable	30	N	16x20x1(2)(W)	
Unknown, UV	CAE 4036 PA ERWE DD	1005253430-2150E-003	Portable	Portable	30	N	16x20x1(2)(W)	