SCHOOL NAME: 135 Rebecca St.

Repecca St.						Requires Immediate		
Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Time to Complete Check (Minutes)	Attention to Maintain Ventilation (Y/N)	Materials	Comments
Offic Type and Tag	Wodel	Serial Nulliber	Offit Location	Serves	(williates)	(1/N)	Materials	Comments
DTUA	40755000 40404	1404024400	Deeffer	Duil die e	45	NI .	40,2002 TA (4) AV40	Belt Good, Filters need changing to PL, Unit age:
RTU1	48TFE008—101GA	1401G34409	Rooftop	Building	45		16x20x2 TA (4) AX48	2001
EF-1	Unknown	Unknown	Ceiling	Washroom 6	15			
EF-2	Unknown	Unknown	Ceiling	Washroom 10	15	N		
EF-3	Unknown	Unknown	Ceiling	Handicap Washroom	15	N		