## SCHOOL NAME: Shannen Koostachin

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Time to Complete Check (Minutes)  Requires Immediate Attention to Maintain Ventilation (Y/N)		Comments
	DPS016AHMG5DW4		lower roof	school	45 N	13- 18X24X2 pltd	
EF13	Cook dome		lower roof	school	15 N	1-4L210	
EF29	Cook dome		upper roof	school	15 N	1-A20	
RTU3 daikin	DPS012AHMG5DV4		upper roof	school	45 N	6-18X24X2 pltd	
RTU2 daikin	DPS010AHMG5DV4		upper roof	school	45 N	6-18X24X2 pltd	
RTU1 daikin	MPS035FG2DV1CYD2		upper roof	school	45 N	14-24X24X2	
RTU5 daikin	MPS040FG2DV1CYD2		upper roof	school	90 Y	8-24X24X2 pltd 16-18X24X2 pltd	not operating , unit in alarm, high limit duct, vfd not optg
RTU4 daikin	DPS018AHMG5DV4		lower roof	school	45 N	9-18X24X2 pltd	
EF17	Cook dome		lower roof	school	15 N	1-4L190	
EF22	Cook dome		lower roof	school	15 N	1-4L200	